COMPRESSOR DATA SHEET

In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors

Rotary Compressor: Variable Frequency Drive

	MODEL DATA - FO	OR COMPRESSED	AIR		
1	Manufacturer: ELGi				
2	Model Number: EG 18V-150 X Air-cooled Water-cooled		Date: 06/26/2020 Type: SCREW		
		†	# of Stages: 1		
3*	Full Load Operating Pressure	150	psig ^b		
4	Drive Motor Nominal Rating	25	hp		
5	Drive Motor Nominal Efficiency	93.6	percent		
6	Fan Motor Nominal Rating (if applicable)	0.40 X 2	hp		
7	Fan Motor Nominal Efficiency	NA	percent		
	Input Power (kW)	Capacity (acfm) ^{a,d}	Specific Power (kW/100 acfm) ^d		
	23.5	92.0	25.56		
0*	21.6	83.0	26.01		
8*	19.8	74.0	26.72		
	17.9	65.0	27.46		
	15.2	53.0	28.61		
	12.4	42.0	29.59		
9*	Total Package Input Power at Zero Flow c, d	0.00	kW		
10	Isentropic Efficiency	59.97	%		
11	20 0 25 50 Note: Graph is only a	75 100 Capacity(CFM) visual representation of the data in S	125		

*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator is being for a list of participants in the third party verification program: www.cagi.org



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E;
 ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%,
- manufacturer may state "not significant" or "0" on the test report. d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:
 - NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

	lume Flow Rate	Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power
m ³ / min	ft ³ / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	+/- 10%
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 031.1

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data