COMPRESSOR DATA SHEET In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors **Rotary Compressor: Variable Frequency Drive MODEL DATA - FOR COMPRESSED AIR** 1 Manufacturer: ELGi Model Number: EG 18V-175 Date 06/26/2020 X SCREW 2 Air-cooled Water-cooled Type # of Stages: 1 psig^b Full Load Operating Pressure^b 3* 175 4 Drive Motor Nominal Rating 25 hp 93.6 5 Drive Motor Nominal Efficiency percent Fan Motor Nominal Rating (if applicable) 0.40 X 2 6 hp 7 Fan Motor Nominal Efficiency NA percent Specific Power Capacity (acfm)^{a,d} Input Power (kW) $(kW/100 acfm)^d$ 82.0 23.7 28.93 21.1 73.0 28.84 8* 19.1 66.0 28.99 17.2 59.0 29.17 15.3 47.0 32.49 12.4 37.0 33.59 Total Package Input Power at Zero Flow c, d 9* 0.00 kW 10 Isentropic Efficiency 58.96 % 40 Power(kW/100CFM) 35 30 25 11 Specific 20 15 10 75 100 125 25 50 Capacity(CFM) Note: Graph is only a visual representation of the data in Section 8 Note: Y-Axis Scale, 10 to 35, + 5kW/100acfm increments if necessary above 35 X-Axis Scale, 0 to 25% over maximum capacity *For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator bsite for a list of participants in the third party verification program: www.cagi.org a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; ACFM is actual cubic feet per minute at inlet conditions. Compressed Air & Gas Institute b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet. c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report. d. Tolerance is specified in ISO 1217, Annex E, as shown in table below: NOTE: The terms "power" and "energy" are synonymous for purposes of this document. Member No Load / Volume Flow Rate Specific Energy Zero Flow at specified conditions Volume Flow Rate Consumption Power m^3 / min ft³ / min % % % Below 0.5 Below 17.6 +/- 7 +/- 8

2/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data

+/- 6

+/- 5

+/- 4

+/- 7

+/- 6

+/- 5

+/- 10%

0.5 to 1.5

1.5 to 15

Above 15

ROT 031.1

17.6 to 53

53 to 529.7

Above 529.7