## COMPRESSOR DATA SHEET

## In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors

Rotary Compressor: Variable Frequency Drive

	MODEL DATA - FO	OR COMPRESSED	AIR		
1	Manufacturer: <b>ELGi</b>				
2	Model Number: EG 200 WV-125  Air-cooled X Water-cooled		Date:	06/26/2020 SCREW	
	An-cooled water-cooled		# of Stages:	1	
3*	Full Load Operating Pressure <sup>b</sup>	125	psig		
4	Drive Motor Nominal Rating	250	hp		
5	Drive Motor Nominal Efficiency	96.2	percent		
6	Fan Motor Nominal Rating (if applicable)	0.40 X 1	hp		
7	Fan Motor Nominal Efficiency	NA	percent		
,	Input Power (kW)	Capacity (acfm) <sup>a,d</sup>	Specific Power		
	input i ower (k w)		(kW/100 acfm) <sup>d</sup>		
	217.6	1175.0	18.51		
8*	192.8	1046.0	18.43		
0	161.5	861.0	18.76		
	145.9	771.0	18.93		
	122.4	638.0	19.19		
	99.0	506.0	19.57		
9*	Total Package Input Power at Zero Flow c, d	0.00	kW		
10	Isentropic Efficiency	79.25	%		
11	25 20 20 20 20 20 20 20 20 20 20 20 20 20	Capacity(CFM) visual representation of the data in	1,125 Section 8		
	Note: Y-Axis Scale, 10 to 35	visual representation of the data in 5, + 5kW/100acfm increments if neces e, 0 to 25% over maximum capacity	Section 8 ssary above 35		

\*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator bisite for a list of participants in the third party verification program: <a href="www.cagi.org">www.cagi.org</a>



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E;
   ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%,
- manufacturer may state "not significant" or "0" on the test report. d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy  Consumption	No Load / Zero Flow Power	
m <sup>3</sup> / min	ft <sup>3</sup> / min	%	%	%	
Below 0.5	Below 17.6	+/- 7	+/- 8		
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%	
1.5 to 15	53 to 529.7	+/- 5	+/- 6	+/- 10%	
Above 15	Above 529.7	+/- 4	+/- 5		

ROT 031.1

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data