COMPRESSOR DATA SHEET

In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors

Rotary Compressor: Variable Frequency Drive

Manufacturer: ELGi Model Number: EG 2: X Air-cooled Full Load Operating Presenting Motor Nominal Rain Moto	2V-125 Water-cooled		Date: Type: # of Stages:	06/2v6/2020 SCREW	
X Air-cooled Full Load Operating Pres	Water-cooled		Type:		
Drive Motor Nominal Ra	ssure		# of Stages:		
Drive Motor Nominal Ra	ssure		# 01 Stages.	psig ^b	
		125			
		93.6		hp	
Drive Motor Nominal Efficiency For Motor Nominal Pating (if applicable)		0.40 X 2		percent hp	
Fan Motor Nominal Rating (if applicable) Fan Motor Nominal Efficiency		NA		percent	
Input Power (kW)		Capacity (acfm) ^{a,d}		Specific Power kW/100 acfm) ^d	
28.2		134.0		21.03	
8* 26.4 24.0		118.0		22.34	
		106.0		22.65	
21.8	21.8			22.91	
18.4		78.0		23.53	
15.3		56.0		27.39	
Total Package Input Pow	er at Zero Flow c, d	0.00	kW		
Isentropic Efficiency		64.01	%		
Specific Power(kW/100CFM) 25 - 5 - 5 - 5 - 5 - 5 - 5 - 5 - 5 - 5					
		20	10		

*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator is being for a list of participants in the third party verification program: www.cagi.org



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E;
 ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%,
- manufacturer may state "not significant" or "0" on the test report. d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

	lume Flow Rate	Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power
m ³ / min	ft ³ / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	±/- 10%
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 031.1

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data