## **COMPRESSOR DATA SHEET**

## In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors

Rotary Compressor: Variable Frequency Drive

MODEL DATA - FOR COMPRESSED AIR							
1	Manufacturer: <b>ELGi</b>						
2	Model Number: EG 37 V-125  X Air-cooled Water-cooled		Date: 06/26/2020  Type: SCREW				
		;	# of Stages: 1				
3*	Full Load Operating Pressure	125	psig				
4	Drive Motor Nominal Rating	50	hp				
5	Drive Motor Nominal Efficiency	94.5	percent				
6	Fan Motor Nominal Rating (if applicable) 2.9		hp				
7	Fan Motor Nominal Efficiency	NA	percent				
	Input Power (kW)	Capacity (acfm) <sup>a,d</sup>	Specific Power (kW/100 acfm) <sup>d</sup>				
	43.0	212.0	20.28				
l	39.3	177.0	22.21				
8*	36.4	159.0	22.86				
	32.7	143.0	22.87				
	20.4	80.0	25.53				
	15.9	54.0	29.52				
9*	Total Package Input Power at Zero Flow c, d	0.00	kW				
10	Isentropic Efficiency	66.19	%				
11	Note: Y-Axis Scale, 10 to 35	150 Capacity(CFM) visual representation of the data in S. + SkW/100acfm increments if neces. 0 to 25% over maximum capacity	225 Section 8 Sarry above 35				

\*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator bisite for a list of participants in the third party verification program: <a href="www.cagi.org">www.cagi.org</a>



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

	lume Flow Rate	Volume Flow Rate	Specific Energy  Consumption	No Load / Zero Flow Power
m <sup>3</sup> / min	ft <sup>3</sup> / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	±/- 10%
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 031.1

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data