COMPRESSOR DATA SHEET



In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors

Rotary Compressor: Variable Frequency Drive

	MODEL DATA - FO	OR COMPRESSED	AIR	
1	Manufacturer: ELGi			
	Model Number: EG 37-175 V		Date:	12/06/2021
2	X Air-cooled Water-cooled		Туре:	SCREW
			# of Stages:	1
3*	Full Load Operating Pressure	175		psig b
4	Drive Motor Nominal Rating	50	hp	
5	Drive Motor Nominal Efficiency	94.5	percent	
6	Fan Motor Nominal Rating (if applicable)	2.9	hp	
7	Fan Motor Nominal Efficiency	NA	percent	
	Input Power (kW)	Capacity (acfm) ^{a,d}	Specific Power (kW/100 acfm) ^d	
	44.2	172.0	25.69	
O.W	42.5	157.0	27.10	
8*	38.9	141.0	27.59	
	34.8	126.0	27.62	
	25.1	79.0	31.77	
	24.3	75.0	32.40	
9*	Total Package Input Power at Zero Flow c, d	0.00	kW	
10	Isentropic Efficiency	62.72	%	
11		100 150 Capacity(CFM)	200	
	Note: Graph is only a Note: Y-Axis Scale, 10 to 3:	Capacity(CFM) visual representation of the data in 5, + 5kW/100acfm increments if neces e, 0 to 25% over maximum capacity		

*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator bsite for a list of participants in the third party verification program: www.cagi.org

- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; ACFM is actual cubic feet per minute at inlet conditions.

 b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.

 c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.

 d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

- NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

Vo	lume Flow Rate		Specific Energy		
at specified conditions		Volume Flow Rate	Consumption	Power	
$\underline{\mathbf{m}}^3 / \underline{\mathbf{min}}$	ft³ / min	%	%	%	
Below 0.5	Below 17.6	+/- 7	+/- 8		
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%	
1.5 to 15	53 to 529.7	+/- 5	+/- 6	+/- 10%	
Above 15	Above 529.7	+/- 4	+/- 5		

ROT 031.1

2/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data