COMPRESSOR DATA SHEET



In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors

Rotary Compressor: Variable Frequency Drive

1 Manufactur	er: ELGi			
	er: ELGI			
Model Num	nber: EG 90V-115-P		Date:	06/15/2022
2 X	Air-cooled Water-cooled		Type:	SCREW
		7	of Stages:	1
3* Full Load C	Operating Pressure b	115		psig ^b
	r Nominal Rating	125	hp	
5 Drive Moto	r Nominal Efficiency	95.4	percent	
6 Fan Motor	Nominal Rating (if applicable)	2.1	hp	
7 Fan Motor	Nominal Efficiency	NA	percent	
	Input Power (kW)	Capacity (acfm) ^{a,d}	Specific Power	
	Imput I ower (it w)		(1	kW/100 acfm) ^d
	101.3	551.0	18.39	
8*	82.7	448.0	18.47	
	67.3	361.0	18.65	
	61.9 54.5	321.0 276.0	19.27 19.74	
	47.3	233.0		
		0.00		20.32
	ů i		kW	
10 Isentropic E	Efficiency	75.67	%	
11		250 375 5 Capacity(CFM) visual representation of the data in S	000	

*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator bisite for a list of participants in the third party verification program: www.cagi.org



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E;
 ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%,
- manufacturer may state "not significant" or "0" on the test report. d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power	
m ³ / min	ft ³ / min	%	%	%	
Below 0.5	Below 17.6	+/- 7	+/- 8		
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%	
1.5 to 15	53 to 529.7	+/- 5	+/- 6	+/- 10%	
Above 15	Above 529.7	+/- 4	+/- 5		

ROT 031.1

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data