COMPRESSOR DATA SHEET

In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors

Rotary Compressor: Variable Frequency Drive

	MODEL DATA - F	OR COMPRESSED	AIR		
1 N	Manufacturer: ELGi				
2 N	Model Number: EG90WV-175P Air-cooled X Water-cooled		Date:	06/26/2020 SCREW	
			# of Stages:	1	
3* F	Full Load Operating Pressure b	175	psig ^b		
	Drive Motor Nominal Rating	125	hp		
5 D	Drive Motor Nominal Efficiency	95.4	percent		
6 F	Fan Motor Nominal Rating (if applicable)	0.3754 X 1	hp		
7 F	Fan Motor Nominal Efficiency	NA	percent		
	Input Power (kW)	Capacity (acfm) ^{a,d}	Specific Power (kW/100 acfm) ^d		
	105.9	426.0	24.85		
8*	97.3	388.0	25.07		
8.	88.7	350.0	25.34		
	80.2	312.0	25.71		
	62.6	238.0	26.31		
	54.2	200.0	27.08		
9* T	Гotal Package Input Power at Zero Flow с, d	0.00	kW		
	sentropic Efficiency	68.81	%		
11	35	200 300 Capacity(CFM)	400		

*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator bisite for a list of participants in the third party verification program: www.cagi.org



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%,
- manufacturer may state "not significant" or "0" on the test report. d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:
 - NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power
m ³ / min	ft ³ / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	±/- 10%
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 031.1

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data