COMPRESSOR DATA SHEET

Federal Uniform Test Method for Certain Air Compressors Not Applicable

Rotary Compressor: Variable Frequency Drive MODEL DATA - FOR COMPRESSED AIR Manufacturer: 1 ELGi **OF200V-100** Date: 06/26/2020 Model Number: X Water-cooled 2 Air-cooled Type: SCREW X Oil Free Lubricated # of Stages: Full Load Operating Pressure^t psig^b 3* 100 4 Drive Motor Nominal Rating 300 hp 5 Drive Motor Nominal Efficiency 95.8 percent 6 Fan Motor Nominal Rating (if applicable) NA hp NA 7 Fan Motor Nominal Efficiency percent Specific Power Capacity (acfm)^{a,d} Input Power (kW) $(kW/100 acfm)^d$ 239.0 1351.0 17.69 226.5 1267.0 17.88 8* 223.0 1229.0 18.15 217.3 1192.0 18.23 210.3 1150.0 18.29 201.0 1095.0 18.35 Total Package Input Power at Zero Flow 9* 0.00 kW 35 Power(kW/100CFM) 30 25 10 20 Specific 15 10 250 1,250 500 750 1,000 Capacity(CFM) Note: Graph is only a visual representation of the data in Section 8 e: Y-Axis Scale, 10 to 35, + 5kW/100acfm increments if necessary above 35 X-Axis Scale, 0 to 25% over maximum capacity Note *For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: www.cagi.org



 Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; ACFM is actual cubic feet per minute at inlet conditions.

- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%,
 - manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:
- NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

		low Rate at specified conditions	Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power
	<u>m³ / min</u>	<u>ft³ / min</u>	%	%	%
	Below 0.5	Below 17.6	+/- 7	+/- 8	+/- 10%
	0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	
	1.5 to 15	53 to 529.7	+/- 5	+/- 6	
ROT 031.2	Above 15	Above 529.7	+/- 4	+/- 5	

12/19 R3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data