## **COMPRESSOR DATA SHEET**

## Federal Uniform Test Method for Certain Air Compressors Not Applicable

**Rotary Compressor: Variable Frequency Drive** 

MODEL DATA - FOR COMPRESSED AIR								
1	Manufacturer: EI	LGi						
	Model Number: Ol	F300V-115	Date:	06/26/2020				
2	Air-cooled X Water-cooled				SCREW			
	Lubricated	d X Oil Free		# of Stages:				
3*	Full Load Operating l	Pressure <sup>b</sup>	115	psig b				
4	Drive Motor Nominal	1 Rating	400	hp				
5	Drive Motor Nominal	1 Efficiency	96.2	percent				
6	Fan Motor Nominal F	Rating (if applicable)	NA	hp				
7	Fan Motor Nominal E	Efficiency	NA	percent				
	Input Power (kW)		Capacity (acfm) <sup>a,d</sup>	Specific Power (kW/100 acfm) <sup>d</sup>				
	312.5		1680.0	18.60				
8*		283.8		18.9				
0.	269.8		1418.0	19.0	03			
	24	12.9	1267.0	19.3	17			
	228.9		1193.0	19.3	18			
	20	3.0	1050.0	19.3	33			
9*	Total Package Input I	Power at Zero Flow c, d	0.00	kW				
10	Specific Power(kW/100CFM)	Note: Graph is only a v Note: Y-Axis Scale, 10 to 35,	900 1,200 Capacity(CFM) visual representation of the data in , + 5kW100acfm increments if neces , 0 to 25% over maximum capacity					

NOTES:



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E;
   ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:
- NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power
m³/min	ft <sup>3</sup> / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	1/ 100/
1.5 to 15	53 to 529.7	+/- 5	+/- 6	+/- 10%
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 031.2

12/19 R3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.

<sup>\*</sup>For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: <a href="www.cagi.org">www.cagi.org</a>