## **COMPRESSOR DATA SHEET**

## Federal Uniform Test Method for Certain Air Compressors Not Applicable

**Rotary Compressor: Variable Frequency Drive** 

MODEL DATA - FOR COMPRESSED AIR								
1	Manufacturer: EI	LGi						
	Model Number: OF300V-125				06/26/2020			
2	Air-cooled X Water-cooled				SCREW			
	Lubricated		# of Stages: 2					
3*	Full Load Operating l	Pressure <sup>b</sup>	125	psig				
4	Drive Motor Nominal	1 Rating	400	hp				
5	Drive Motor Nominal	1 Efficiency	96.2	percent				
6	Fan Motor Nominal F	Rating (if applicable)	NA	hp				
7	Fan Motor Nominal E	Efficiency	NA	percent				
	Input Power (kW)		Capacity (acfm) <sup>a,d</sup>	Specific Power (kW/100 acfm) <sup>d</sup>				
	319.6		1646.0	19.42				
0*		9.7	1485.0	19.				
8*	26	260.6		19.0	68			
	24	6.5	1246.0	19.7	78			
	217.4		1095.0	19.8	86			
	204.4		1023.0	19.9	98			
9*	Total Package Input Power at Zero Flow c, d		0.00	kW				
10	■ Specific Power(kw/100CFM)	Note: Graph is only a v Note: Y-Axis Scale, 10 to 35,	975 1,300  Capacity(CFM)  visual representation of the data in , + 5kW/100acfm increments if neces , 0 to 25% over maximum capacity					

NOTES:



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E;
   ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power	
m <sup>3</sup> / min	ft <sup>3</sup> / min	%	%	%	
Below 0.5	Below 17.6	+/- 7	+/- 8		
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%	
1.5 to 15	53 to 529.7	+/- 5	+/- 6		
Above 15	Above 529.7	+/- 4	+/- 5		

ROT 031.2 12/19 R3

This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.

<sup>\*</sup>For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: <a href="www.cagi.org">www.cagi.org</a>