COMPRESSOR DATA SHEET

Federal Uniform Test Method for Certain Air Compressors Not Applicable

Rotary Compressor: Variable Frequency Drive

MODEL DATA - FOR COMPRESSED AIR								
1	Manufacturer: EI	LGi						
	Model Number: OF55AV-115			Date:	06/26/2020			
2	X Air-cooled		Type:	SCREW				
	Lubricated X Oil Free			# of Stages: 2				
3*	Full Load Operating I	Pressure	115	psig ^b				
4	Drive Motor Nominal	l Rating	75	hp				
5	Drive Motor Nominal	l Efficiency	93.6	percent				
6	Fan Motor Nominal R	Rating (if applicable)	4.95 x 1	hp				
7	Fan Motor Nominal F			percent				
	Input Power (kW)		Capacity (acfm) ^{a,d}	Specific Power (kW/100 acfm) ^d				
	71.5		268.0	26.67				
8*	67.		253.0	26.				
8	64.9		241.0	26.9	94			
	63	63.8		27.2	26			
	62.1		227.0	27.3	38			
	59.		209.0	28.4	41			
9*	Total Package Input F	Total Package Input Power at Zero Flow c, d		kW				
10	Specific Power(kW/100CFM)	Note: Y-Axis Scale, 10 to 35	150 225 Capacity(CFM) visual representation of the data in 5, + 5kW/100acfm increments if neces e, 0 to 25% over maximum capacity					

NOTES:



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E;
 ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:
- NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power	
m³/min	ft ³ / min	%	%	%	
Below 0.5	Below 17.6	+/- 7	+/- 8		
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	1/ 100/	
1.5 to 15	53 to 529.7	+/- 5	+/- 6	+/- 10%	
Above 15	Above 529.7	+/- 4	+/- 5		

ROT 031.2 12/19 R3

This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.

^{*}For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: www.cagi.org