## COMPRESSOR DATA SHEET



## In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors

Rotary Compressor: Variable Frequency Drive

	MODEL DATA - I	FOR COMPRESSED	AIR		
1	Manufacturer: <b>ELGi</b>				
2	Model Number: <b>EG 200 V-115</b> X Air-cooled Water-cooled		Date:	06/04/2021 SCREW	
		# of Stages:		1	
3*	Full Load Operating Pressure <sup>b</sup>	115	psig <sup>b</sup>		
4	Drive Motor Nominal Rating	250	hp		
5	Drive Motor Nominal Efficiency	96.2	percent		
6	Fan Motor Nominal Rating (if applicable)	1.88 X 3	hp		
7	Fan Motor Nominal Efficiency	NA	percent		
	Input Power (kW)	Capacity (acfm) <sup>a,d</sup>	Specific Power (kW/100 acfm) <sup>d</sup>		
	220.1	1192.0	18.46		
0*	190.7	1060.0	17.99		
8*	160.2	857.0	18.69		
	145.0	763.0	19.00		
	122.1	623.0	19.60		
	99.3	493.0	20.14		
9*	Total Package Input Power at Zero Flow c, d	0.00	kW		
10	Isentropic Efficiency	75.45	%		
11	Note: Graph is only	50 675 900  Capacity(CFM)  y a visual representation of the data in S 35, + 5kW/100acfm increments if necess	1,125 Section 8		

\*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator is being for a list of participants in the third party verification program: <a href="https://www.cagi.org">www.cagi.org</a>



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E;
   ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy  Consumption	No Load / Zero Flow Power
m <sup>3</sup> / min	ft <sup>3</sup> / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	±/- 10%
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 031.1

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data