## COMPRESSOR DATA SHEET



## In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors

**Rotary Compressor: Variable Frequency Drive** 

1	Manufacturer: <b>ELGi</b>			
	Model Number: EG 110V-150-P		Date:	06/03/2022
2	X Air-cooled Water-cooled		Type:	SCREW
		#	of Stages:	1
3*	Full Load Operating Pressure	150	or suges.	psig <sup>b</sup>
4	Drive Motor Nominal Rating	150	hp	
5	Drive Motor Nominal Efficiency	95.8	percent	
6	Fan Motor Nominal Rating (if applicable)	2.1 X 2	hp	
7	Fan Motor Nominal Efficiency	NA	percent	
	Input Power (kW)	Capacity (acfm) <sup>a,d</sup>	Specific Power	
	input Fower (RW)		(kW/100 acfm) <sup>d</sup>	
	127.4	595.0	21.42	
8*	116.0	537.0	21.59	
0	105.5	484.0	21.80	
	95.9	432.0	22.20	
	75.2	318.0	23.66	
	66.4	276.0	24.07	
9*	Total Package Input Power at Zero Flow c, d	0.00	kW	
10	Isentropic Efficiency	73.17	%	
11	Note: Graph is only a v	0 375 500 Capacity(CFM) visual representation of the data in S	625	

\*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator bisite for a list of participants in the third party verification program: <a href="www.cagi.org">www.cagi.org</a>



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E;
   ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy  Consumption	No Load / Zero Flow Power
m <sup>3</sup> / min	ft <sup>3</sup> / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	1/ 100/
1.5 to 15	53 to 529.7	+/- 5	+/- 6	+/- 10%
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 031.1

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data