## **COMPRESSOR DATA SHEET**

## Federal Uniform Test Method for Certain Air Compressors Not Applicable

**Rotary Compressor: Fixed Speed** 

MODEL DATA - FOR COMPRESSED AIR						
1	Manufacturer: ELGi					
	Model Number: OF 132-100	Date:	03/01/2023			
2	Air-cooled X Water-cooled	Туре:	SCREW			
	Oil-injected X Oil-free	# of Stages:	2			
3*	Rated Capacity at Full Load Operating Pressure a, e	865	acfm <sup>a,e</sup>			
4	Full Load Operating Pressure b	100	b psig			
5	Maximum Full Flow Operating Pressure c	103	psig c			
6	Drive Motor Nominal Rating	200	hp			
7	Drive Motor Nominal Efficiency 95.4		percent			
8	Fan Motor Nominal Rating (if applicable)	hp				
9	Fan Motor Nominal Efficiency	percent				
10*	Total Package Input Power at Zero Flow <sup>e</sup> 30.60		kW <sup>e</sup>			
11	Total Package Input Power at Rated Capacity and Full Load Operating Pressure <sup>d</sup>	149.49	$kW^d$			
12*	Specific Package Input Power at Rated Capacity and Full Load Operating Pressure   17.28		kW/100 cfm <sup>e</sup>			

NOTES

- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex C; ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 3) and Electrical Consumption (Item 11) were measured for this data sheet.
- c. Maximum pressure attainable at full flow, usually the unload pressure setting for load/no load control or the maximum pressure attainable before capacity control begins. May require additional power.
- d. Total package input power at other than reported operating points will vary with control strategy.
- e. Tolerance is specified in ISO 1217, Annex C, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.



Member

ROT 030.2

12/19 Rev 3

	Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy  Consumption	No Load / Zero Flow Power
Ī	$\underline{m^3 / min}$	ft <sup>3</sup> / min	%	%	%
	Below 0.5	Below 17.6	+/- 7	+/- 8	
	0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
	1.5 to 15	53 to 529.7	+/- 5	+/- 6	+/- 10%
	Above 15	Above 529.7	+/- 4	+/- 5	

This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.

<sup>\*</sup>For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator.

Consult CAGI website for a list of participants in the third party verification program:

www.cagi.org