COMPRESSOR DATA SHEET



Federal Uniform Test Method for Certain Air Compressors Not Applicable

Rotary Compressor: Variable Frequency Drive

				Variable Frequency			
1	Manufac	turer: ELG	i				
	Model N	Model Number: OF145V-145				Date: 03/01/2023	
2		Air-cooled	X Water-cooled			SCREW	
		Lubricated			# of Stages:		
3*		Full Load Operating Pressure		145		psig	
4		Drive Motor Nominal Rating		200		hp	
5		otor Nominal Ef	-	95.4		percent	
6			ng (if applicable)			hp	
7	Fan Mote	or Nominal Effic	NA		percent		
		Input Pow	ver (kW)	Capacity (acfm) ^{a,d}		Specific Power (kW/100 acfm) ^d	
		160.3		720.0	22.2	22.26	
8*		156.1	699.0		22.33		
	*	152.4	678.0	22.4	22.47		
		146.9	651.0	22.4	22.57		
		142.2	624.0		22.79		
		138.0		598.0	23.	23.08	
9*	* Total Pa	ckage Input Pow	er at Zero Flow ^{c, d}	0.00		kW	
10	0	25 20 20 20 15 10 0 150 300 450 600 750 Capacity(CFM) Note: Graph is only a visual representation of the data in Section 8 Note: Y-Axis Scale, 10 to 35, +5kW/100acfm increments if necessary above 35					
				e, 0 to 25% over maximum capacity ogram, these items are verif fication program:	ied by the third		
NO CACE Compressed Air & Gas Institute Member	b. c.	ACFM is actual cut . The operating press . No Load Power. In manufacturer may s . Tolerance is specifi	bic feet per minute at inlet co ure at which the Capacity (It accordance with ISO 1217, tate "not significant" or "0" ed in ISO 1217, Annex E, as	em 8) and Electrical Consump Annex E, if measurement of n on the test report.	tion (Item 8) we o load power equ	re measured for this data sheet.	
wender	Volume	Volume Flow Rate at specified conditions		Specific Energy Consumption	No Load / Zero Flow Power		
	<u>m³ / min</u>	$\underline{\mathrm{ft}}^3 / \mathrm{min}$	%	%	%		
	m ³ /min Below 0.5	<u>ft³ / min</u> Below 17.6	% +/- 7	% +/- 8	%		
	Below 0.5	Below 17.6	+/- 7	+/- 8	% +/- 10%		

This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.

12/19 R3