## **COMPRESSOR DATA SHEET**



## Federal Uniform Test Method for Certain Air Compressors Not Applicable

**Rotary Compressor: Variable Frequency Drive** 

MODEL DATA - FOR COMPRESSED AIR								
1	Manufacturer: <b>ELGi</b>							
	Model Number: <b>OF90V-115</b>		Date:	03/01/2023				
2	Air-cooled X Water-cooled  Lubricated X Oil Free			SCREW				
3*								
-	Full Load Operating Pressure	115	psig					
4	Drive Motor Nominal Rating	125	hp					
5	Drive Motor Nominal Efficiency	95	percent					
6	Fan Motor Nominal Rating (if applicable)	NA	hp					
7	Fan Motor Nominal Efficiency		percent Specific Power					
8*	Input Power (kW)	Capacity (acfm) <sup>a,d</sup>	(kW/100 acfm) <sup>d</sup>					
	112.2	533.0	21.04					
	106.9	496.0	21.5	56				
0	101.1	464.0	21.8	80				
	95.3	437.0	21.8	32				
	90.1	409.0	22.0	02				
	78.2	349.0	22.3	39				
9*	Total Package Input Power at Zero Flow c, d	0.00		kW				
10	Note: Graph is only a v Note: Y-Axis Scale, 10 to 35	i0 375 500 Capacity(CFM)  risual representation of the data in: , + 5kW/100acfm increments if neces , 0 to 25% over maximum capacity						

\*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: <a href="www.cagi.org">www.cagi.org</a>

NOTES:



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E;
   ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power	
m³/min	ft <sup>3</sup> / min	%	%	%	
Below 0.5	Below 17.6	+/- 7	+/- 8		
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	. / 100/	
1.5 to 15	53 to 529.7	+/- 5	+/- 6	+/- 10%	
Above 15	Above 529.7	+/- 4	+/- 5		

ROT 031.2

12/19 R3

This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.