COMPRESSOR DATA SHEET



Federal Uniform Test Method for Certain Air Compressors Not Applicable

Rotary Compressor: Variable Frequency Drive

MODEL DATA - FOR COMPRESSED AIR							
1	Manufacturer: ELGi						
	Model Number: OF90V-145		Date:	03/01/2023			
2	Air-cooled X Water-cooled		Type:	SCREW			
	Lubricated X Oil Free	# of Stages: 2					
3*	Full Load Operating Pressure	145		psig b			
4	Drive Motor Nominal Rating	125		hp			
5	Drive Motor Nominal Efficiency	95	percent				
6	Fan Motor Nominal Rating (if applicable)		hp				
7	Fan Motor Nominal Efficiency	NA	percent				
	Input Power (kW)	Capacity (acfm) ^{a,d}	Specific Power				
			(kW/100 acfm) ^d				
	115.4	452.0	25.5				
8*	107.4 105.5	418.0	25.0 25.8				
	103.5	395.0	25.9				
	102.0	382.0	26.3				
	97.4	365.0	26.0				
9*	Total Package Input Power at Zero Flow c, d 0.00		kW				
10	35 30 20 20 15 0 100 20 C Note: Graph is only a vi Note: Y-Axis Scale, 10 to 35,	0 300 400 apacity(CFM) sual representation of the data in ences 0 to 25% over maximum capacity	Section 8				

NOTES:



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E;
 ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:
- NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power
m ³ / min	ft ³ / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	./ 100/
1.5 to 15	53 to 529.7	+/- 5	+/- 6	+/- 10%
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 031.2

^{*}For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: www.cagi.org