COMPRESSOR DATA SHEET



Federal Uniform Test Method for Certain Air Compressors Not Applicable

Rotary Compressor: Variable Frequency Drive

MODEL DATA - FOR COMPRESSED AIR								
1	Manufacturer: ELGi							
	Model Number: OF110AV-145		Date:	08/17/2023				
2	X Air-cooled Water-cooled		Type:	SCREW				
	Lubricated X Oil Free		# of Stages: 2					
3*	Full Load Operating Pressure	145	psig					
4	Drive Motor Nominal Rating	150	hp					
5	Drive Motor Nominal Efficiency	95	percent					
6	Fan Motor Nominal Rating (if applicable)	2.1 x 2	hp					
7	Fan Motor Nominal Efficiency	NA	percent					
8*	Input Power (kW)	Capacity (acfm) ^{a,d}	Specific Power (kW/100 acfm) ^d					
	134.2	527.0	25.46					
	123.1	466.0	26.41					
8"	117.3	436.0	26.9	93				
	110.1	405.0	27.18					
	106.4 382.0		27.82					
	102.1	360.0	28.39					
9*	Total Package Input Power at Zero Flow c, d	0.00	kW					
10	35 (W) 30	250 375 apacity(CFM) isual representation of the data in + 5kW/100acfm increments if neces 0 to 25% over maximum capacity	500 Section 8 Seary above 35					

NOTES:



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E;
 ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power	
m³/min	ft ³ / min	%	%	%	
Below 0.5	Below 17.6	+/- 7	+/- 8		
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	1/ 100/	
1.5 to 15	53 to 529.7	+/- 5	+/- 6	+/- 10%	
Above 15	Above 529.7	+/- 4	+/- 5		

ROT 031.2

12/19 R3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.

^{*}For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: www.cagi.org