COMPRESSOR DATA SHEET Federal Uniform Test Method for Certain Air Compressors Not Applicable

Rotary Compressor: Fixed Speed

MODEL DATA - FOR COMPRESSED AIR

	Model Number: OF145A-115	Date:	10/18/2023	
2	X Air-cooled Water-cooled	Type:	SCREW	
	Oil-injected X Oil-free	# of Stages:	2	
3*	Rated Capacity at Full Load Operating Pressure a, e	873	acfm ^{a,e}	
4	Full Load Operating Pressure ^b	115	psig ^b	
5	Maximum Full Flow Operating Pressure ^c	118	psig ^c	
6	Drive Motor Nominal Rating	200	hp	
7	Drive Motor Nominal Efficiency	95.4	percent	
8	Fan Motor Nominal Rating (if applicable)	3.9 x 2	hp	
9	Fan Motor Nominal Efficiency	NA	percent	
10*	Total Package Input Power at Zero Flow ^e	39.80	kW ^e	
11	Total Package Input Power at Rated Capacity and Full Load Operating Pressure ^d	178.06	kW^d	
12*	Specific Package Input Power at Rated Capacity and Full Load Operating Pressure ^e	20.40	kW/100 cfm ^e	

Consult CAGI website for a list of participants in the third party verification program: www.cagi.org

NOTES:

CVU

RO

- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex C; ACFM is actual cubic feet per minute at inlet conditions.b. The operating pressure at which the Capacity (Item 3) and Electrical Consumption (Item 11) were measured for this data sheet.
- c. Maximum pressure attainable at full flow, usually the unload pressure setting for load/no load control or the maximum pressure attainable before capacity control begins. May require additional power.
- d. Total package input power at other than reported operating points will vary with control strategy.
- e. Tolerance is specified in ISO 1217, Annex C, as shown in table below:
- NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Compressed Air & Gas Institute		Volume Flow Rate		Specific Energy	No Load / Zero Flow
and the second se	at specified conditions		Volume Flow Rate	Consumption	Power
	<u>m³ / min</u>	<u>ft³ / min</u>	%	%	%
Member	Below 0.5	Below 17.6	+/- 7	+/- 8	
	0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	1.00/
	1.5 to 15	53 to 529.7	+/- 5	+/- 6	+/- 10%
030.2	Above 15	Above 529.7	+/- 4	+/- 5	

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.