## **COMPRESSOR DATA SHEET**



## Federal Uniform Test Method for Certain Air Compressors Not Applicable

**Rotary Compressor: Variable Frequency Drive** 

MODEL DATA - FOR COMPRESSED AIR								
1	Manufacturer: <b>ELGi</b>							
	Model Number: <b>OF145AV-100</b>		Date:	10/18/2023				
2	X Air-cooled Water-cooled		Type:	SCREW				
	Lubricated X Oil Free		# of Stages: 2					
3*	Full Load Operating Pressure b	100	psig					
4	Drive Motor Nominal Rating	200	hp					
5	Drive Motor Nominal Efficiency	95.4	percent					
6	Fan Motor Nominal Rating (if applicable)	3.9 x 2	hp					
7	Fan Motor Nominal Efficiency	NA	percent					
8*	Input Power (kW)	Capacity (acfm) <sup>a,d</sup>	Specific Power (kW/100 acfm) <sup>d</sup>					
	180.5	940.0	19.20					
	157.5	788.0	19.9	99				
8.	145.2	712.0	20.39					
	131.8	636.0	20.73					
	124.7 593.0		21.03					
	117.2	550.0	21.31					
9*	Total Package Input Power at Zero Flow c, d	0.00	kW					
10	Total Funding Impact Fower at 2200 Frow   0.000   R.W    35							

NOTES:



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E;
   ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power	
m³/min	ft <sup>3</sup> / min	%	%	%	
Below 0.5	Below 17.6	+/- 7	+/- 8		
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	. / 100/	
1.5 to 15	53 to 529.7	+/- 5	+/- 6	+/- 10%	
Above 15	Above 529.7	+/- 4	+/- 5		

ROT 031.2

<sup>\*</sup>For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: <a href="www.cagi.org">www.cagi.org</a>