COMPRESSOR DATA SHEET



In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors

Rotary Compressor: Variable Frequency Drive

	MODEL DATA - F	OR COMPRESSED	AIR	
1	Manufacturer: ELGi			
	Model Number: EG 75-175V		Date:	12/20/2022
2	X Air-cooled Water-cooled		Type:	SCREW
		:	# of Stages:	1
3*	Full Load Operating Pressure	175	psig ^b	
4	Drive Motor Nominal Rating	100	hp	
5	Drive Motor Nominal Efficiency	95.4	percent	
6	Fan Motor Nominal Rating (if applicable)	2.07 (1.55) - (460)	V) X 1 Fans hp	
7	Fan Motor Nominal Efficiency	NA	percent	
	Input Power (kW)	Capacity (acfm) A,d (kW/100 acfm)		Specific Power kW/100 acfm) ^d
	90.3	390.0		23.14
	83.7	357.0		23.44
8*	76.5	324.0		23.62
	69.1	289.0	23.92	
	61.8	253.0	24.43	
	41.4	149.0	27.81	
9*	Total Package Input Power at Zero Flow c, d	0.00	kW	
10	Isentropic Efficiency	72.68	%	
11	35 00 10 10 75 150 Note: Graph is only a Note: Y-Axis Scale, 10 to 3 X-Axis Scale,	225 300 Capacity(CFM) visual representation of the data in 5, + 5kW/100ac/m increments if neces	375 Section 8	

*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator bisite for a list of participants in the third party verification program: www.cagi.org



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E;
 ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power
m ³ / min	ft ³ / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	+/- 10%
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 031.1

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data